



SHIFTING THE LIMITS

Wels, May 19th 2017

OPERATION AT 240 V

Fronius International GmbH

hereby confirms that the inverter

/ Fronius Primo 3.0-1 – 8.2-1

meets the requirements for anti islanding, overvoltage protection, undervoltage protection and the power factor requirements defined in ABNT NBR 16149 at a grid voltage of 240 V when using one of the following country setups:

/ BR 1 (Brasil 1)

/ BR 2 (Brasil 2)

/ BR 3 (Brasil 3)

Fronius International GmbH

Solar Energy Division

Froniusplatz 1

A-4600 Wels

A handwritten signature in blue ink, appearing to read "Thomas Mühlberger".

DI Thomas Mühlberger
Head of Solution Management